

# Moon Township

## Catchbasin/Stormwater Inlet - BMP Inspection Checklist



Property Address: \_\_\_\_\_

Basin ID: \_\_\_\_\_

Date of Inspection: \_\_\_\_\_

Date of Last Inspection: \_\_\_\_\_

Inspector: \_\_\_\_\_

Maintenance Item	Satisfactory (Yes/No/N.A.)	Comments
<b>Catchbasin/Inlet Grate and Frame</b>		
Is there debris clogging the grate openings?		
Is there sediment build-up near the grate?		
Are there cracks in the grate or frame?		
Is there a filter bag in the inlet?		
If there is a filter bag in the inlet, does it need to be cleaned out?		
<b>Catchbasin/Inlet Riser Structure</b>		
Are there any cracks or spalling in the riser structure?		
Is the mortar around the pipes tight?		
Trash or debris blocking the inlet or outlet pipes?		
Any eroded areas at the base or around the pipes?		
Is there sediment accumulation on the floor of the catchbasin? (Greater than 1/3 the diameter of the lowest pipe requires cleaning)		
Is there ponded water? (Dry weather ponded water requires sparging)		

## Moon Township Catchbasin/Stormwater Inlet - BMP Inspection Checklist



Property Address: \_\_\_\_\_  
 Basin ID: \_\_\_\_\_  
 Date of Inspection: \_\_\_\_\_  
 Date of Last Inspection: \_\_\_\_\_  
 Inspector: \_\_\_\_\_

<b>Maintenance Item</b>	<b>Satisfactory (Yes/No/N.A.)</b>	<b>Comments</b>
Additional Comments/Observations:		
Repairs/Remediation Recommended:		